

# Town of West Point

## 2019 Annual Drinking Water Quality Report



---

### INTRODUCTION

This Annual Drinking Water Quality Report for calendar year 2019 is designed to inform you about your drinking water quality. Our goal is to provide you with a safe and dependable supply of drinking water and we want you to understand the efforts we make to protect your water supply. The quality of your drinking water must meet state and federal requirements administered by the Virginia Department of Health (VDH).

If you have questions about this report, want additional information about any aspect of your drinking water, or want to know how to participate in decisions that may affect the quality of your drinking water, please contact:

**Walter E. Feurer**  
**Director of Public Works**  
329 Sixth Street  
Post Office Box 152  
West Point, Virginia 23181  
(804) 843-4365  
[wfeurer@west-point.va.us](mailto:wfeurer@west-point.va.us)

The West Point Town Council meets at 6:30 P.M. on the last Tuesday of each month in the Town Hall located at 329 Sixth Street.

---

### GENERAL INFORMATION

Drinking water, including bottled drinking water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immune-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. Environmental Protection Agency/ Center for Disease Control (EPA/CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or human activity. Contaminants that may be present in source water include: (1) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic tanks, agricultural livestock operations, and wildlife. (2) Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming. (3) Pesticides and herbicides, which may come from a variety of sources such as agricultural, urban storm water runoff, and residential uses. (4) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can, also come from gas stations, urban storm water runoff, and septic system. (5) Radioactive contaminants, which can be naturally occurring or be the results of oil and gas production and mining activities. To ensure that tap water is safe to drink, EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

---

### DEFINITIONS

Contaminants in drinking water are routinely monitored according to state and federal regulations. The state allows the Town of West Point Water Department to monitor for some contaminants less than once per year. Because concentrations of these contaminants do not change frequently, some of the data, though representative is more than one year old. The following tables show the results of monitoring during the last water quality inspection performed by the Virginia Department of Health, Office of Drinking Water and list only those contaminants that had some level of detection. Many other contaminants have been

analyzed but were not present or were below the detection limits of the lab equipment. Within the tables and elsewhere in this report you will find many terms and abbreviations that might not be familiar.

The following definitions are provided to help you better understand these terms:

- **Action Level (AL):** The concentration of a contaminant, which, when exceeded, triggers treatment or other requirements, which a water system must follow.
- **Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below, which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below, which there is no known or expected risk of health. MCLGs allow for a margin of safety.
- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **N/A:** Not applicable.
- **ND (Non-Detects):** Lab analysis indicates that the contaminant is not present.
- **PPB (Parts per Billion):** Micrograms per liter-one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- **PPM (Parts Per Million):** Milligrams per liter-one part per million corresponds to one minute in two years or a single penny in \$10,000.
- **PCI/L (Picocuries per Liter):** A measure of the radioactivity in water.

## WATER QUALITY RESULTS

### I. Lead and Copper Contaminants

Contaminants	Units of Measurement	Action Level	MCLG	Results of Sample For the 90 <sup>th</sup> Percentile Value	Action Level Exceeded (Y/N)	Month of Sampling	# of Sampling Sites Exceeding Action Level	Typical Source of Contamination
Copper	mg/L	1.3	1.3	0.11	N	7/17	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives.
Lead	ppb	15	0	< 2	N	7/17	0	Corrosion of household plumbing systems; Erosion of natural deposits.

## ADDITIONAL HEALTH INFORMATION

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of West Point Water Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## ASSESSMENT INFORMATION

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct an assessment to identify problems and to correct any problems that are found.

During the past year, we were required to conduct one Level 1 assessment. This Level 1 assessment was completed in October 2018. We were not required to take any corrective actions.

## II. Other Chemical and Radiological Contaminants

Contaminant	Unit of Measurement	MCLG	MCL	Level Detected	Violation (Y/N)	Range of Detection at Sampling Points	Date of Sample	Typical Source of Contamination
Fluoride	ppm	4	4	2.19 (Well #1) 2.13 (Well #2) 1.86 (Well #3)	N	1.86 – 2.19	4/09/18 5/16/17 5/16/17	Erosion of natural deposits; discharge from fertilizer
Gross Beta (*)	PCi/L	0	50	4.7 (Well #1) 4.5 (Well #2) 3.8 (Well #3)	N	3.8 – 4.7	4/15/15 4/15/15 4/15/15	Decay of natural and manmade deposits
Gross Alpha	PCi/L	0	15	<0.9 (Well# 1) 0.8 (Well# 2) <0.7 (Well# 3)	N	<0.9 – 0.8	4/15/15 4/15/15 4/15/15	Erosion of natural deposits
Combined Radium	PCi/L	0	5	<0.5 (Well #1) <0.6 (Well #2) <0.6 (Well #3)	N	<0.6 – <0.5	4/15/15 4/15/15 4/15/15	Erosion of natural deposits
Total Trihalomethanes (TTHM)	ppb	80	80	5.7ppb	N		8/05/19	By-product of drinking water chlorination
Haloacetic Acids (HAA)	ppb	60	60	<1 UG/L	N		8/05/19	By-product of drinking water chlorination

\* The MCL for beta particles is 4 mrem/year. EPA considers 50 PCi/L to be the level of concern for beta particles.

## IV. Disinfectants

Disinfectants	Units of Measurement	MRDLG	MRDL	Level Detected (Annual Average in distribution)	Violation (Y/N)	Range of Detection at Sampling Points	Year	Typical Source
Chlorine	ppm	4	4	.28	N	0.1 – 0.5	2019	Water additive used to control microbes

## SOURCE(S) and TREATMENT OF YOUR DRINKING WATER

Your water comes from three municipal wells that are located within the town. The Town of West Point owns the land around these wells and restricts any activity that could contaminate them. After the water comes out of the wells, we treat it by chlorination to prevent bacteriological growth within the distribution system. As a first step toward protection of our sources of drinking water, the Virginia Department of Health (VDH) evaluated the susceptibility of Virginia's water supplies to contamination. Contamination sources and pathways were reviewed using maps, known and observed activities, water quality data and information about the water source. Using criteria developed by the state in its EPA-approved Source Water Assessment Program, it was determined that on a relative basis, all three wells are of low susceptibility to contamination. A copy of the source water assessment report is available by contacting Mr. Walt Feurer at (804) 843-4365.

## VIOLATION INFORMATION

Your water system did not have any violations during 2019.

## OTHER DRINKING WATER CONSTITUENTS OF INTEREST:

MCL's are set at very stringent levels by the U.S. Environmental Protection Agency. In developing the standards EPA assumes that the average adult drinks 2 liters of water each day throughout a 70-year life span. EPA generally sets MCL's at levels that will result in no adverse health effects for some contaminants or a one-in-ten-thousand to one-in-a-million chance of having the described health effect for other contaminants.

## YOU NEED TO KNOW

The average sodium concentration of samples collected from Wells 1, 2 and 3 on March 16, 2017 and April 9, 2018 was 177.0 ppm. This concentration exceeds the recommended maximum contaminant level of 20 ppm for persons on a "strict" sodium diet.

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER:**

***Elevated Fluoride Levels Detected***

This is an alert about your drinking water and a cosmetic dental problem that might affect children under nine years of age. At low levels, fluoride can help prevent cavities, but children drinking water containing more than 2 milligrams per liter (mg/l) of fluoride may develop cosmetic discoloration of their permanent teeth (dental Fluorosis). The drinking water provided by Town of West Point's Water Department has an average fluoride concentration of 2.1 mg/l\*.

Dental fluorosis in its moderate or severe forms may result in a brown staining and or pitting of the permanent teeth. This problem occurs only in developing teeth, before they erupt from the gums. Children under the age of nine should be provided with alternative sources of drinking water or water that has been treated to remove the fluoride to avoid the possibility of staining and pitting of their permanent teeth. You may also want to contact your dentist about proper use by young children of fluoride-containing products. Older children and adults may safely drink the water.

Drinking water containing more than 4mg/l of fluoride (the U.S. Environmental Protection Agency's drinking water standard) can increase your risk of developing bone disease. Your drinking water does not contain more than 4 mg/l of fluoride, but we're required to notify you when we discover that the fluoride levels in your drinking water exceed 2 mg/l because of this cosmetic dental problem.

\* Tests Performed on 5/16/17 & 4-9-18